

Environment Protection Licence Number 2384.

Warren Shire Council Sewerage Treatment Plant

Oxley Highway
Warren NSW 2824
Lot 1 DP 1163604

Sample collected at EPA Point No. 2. Quarterly.

Pollutant			PH	Total Susspended Solids TSS	Nitrogen Total	Phosphorus Total	Oil & Grease	Biochemical oxygen demand BOD	
Unit of Measure			PH	Milligrams Per Litre					
Limit			6.5 - 8.5	65	40	10	10	55	
Sample Date	Date Results Obtained	Date Results Published	Red text indicates a result outside of the limits.						Comments
8/06/2021	18/06/2021	18/06/2021	8	53	31.9	5.2	6	17	Nitrogen has returned to acceptable level
31/05/2021	8/06/2021	18/06/2021	8	42	34.2	5.36	5	24	Nitrogen has returned to acceptable level
19/05/2021	27/05/2021	31/05/2021	8	45	47.5	5.66	5	19	Addition sample taken 31/05/2021 for testing.
18/02/2021	23/02/2021	1/03/2021	8	64	32.7	4.99	5	21	
18/11/2020	25/11/2020	26/11/2020	8.1	51	32.6	5.43	8	28	
18/08/2020	26/08/2020	26/08/2020	8	64	37.2	4.96	5	55	
26/05/2020	3/06/2020	7/08/2020	8	51	35.1	4.96	7	16	
7/04/2020	16/04/2020	7/08/2020	8	32	34.6	4.35	8	120	Wet weather prior to sample collection
19/11/2019	27/11/2019	7/08/2020	7.9	35	28.7	4.34	5	18	
31/07/2019	8/08/2019	7/08/2020	8.1	31	29.3	4.3	8	33	Due to a technical issue, results prior to 7/08/2020 had been inadvertently removed from the website.
28/05/2019	6/06/2019	7/08/2020	8.1	37	30.7	4.87	10	27	
30/04/2019	8/05/2019	7/08/2020	8	61	23.6	3.6	10	39	
3/04/2019	10/04/2019	7/08/2020	8.1	20	16	3.92	5	2	
18/07/2016	26/06/2016	7/08/2020	8.1	30	31.3	5.3	15	84	
11/05/2016	23/05/2016	7/08/2020	7.9	58	34.1	6.3	2	27	
27/04/2016	11/05/2016	7/08/2020	7.9	36	4.7	5.1	3	33	

Environment Protection Licence Number 2384.

Warren Shire Council Sewerage Treatment Plant

Oxley Highway
Warren NSW 2824
Lot 1 DP 1163604

Sample collected at EPA Point No. 2. Quarterly.

Pollutant			PH	Total Suspended Solids TSS	Nitrogen Total	Phosphorus Total	Oil & Grease	Biochemical oxygen demand BOD	
Unit of Measure			PH	Milligrams Per Litre					
Limit			6.5 - 8.5	65	40	10	10	55	
Sample Date	Date Results Obtained	Date Results Published	Red text indicates a result outside of the limits.						Comments
11/11/2015	18/11/2015	7/08/2020	8	70	27.7	5	2	49	
4/08/2015	10/08/2015	7/08/2020	8.1	54	33.7	4.8	6	44	
3/11/2014	10/11/2014	7/08/2020	7.8	70	35.4	5.4	9	26	
7/08/2014	15/08/2014	7/08/2020	7.95	64	22.8	7.3	2	60	
24/06/2014	4/07/2014	7/08/2020	7.95	152	29.9	4.5	7	56	
16/04/2014	28/04/2014	7/08/2020	7.94	49	31.2	5.7	7	32	
31/07/2013	9/08/2013	7/08/2020	8.02	82	33.4	5.4	5	28	
24/06/2013	1/07/2013	7/08/2020	7.87	40	33.2	4.7	5	18	
6/03/2013	19/03/2013	7/08/2020	7.87	36	23.9	4.7	5	29	
17/12/2012	27/12/2012	7/08/2020	8	46	22.5	4.1	3	21	
19/09/2012	26/09/2012	7/08/2020	7.86	58	42.2	4.7	10	24	
3/04/2012	17/04/2012	7/08/2020	7.91	48	17	3.2	3	35	
6/12/2011	13/12/2011	7/08/2020	7.93	59	20.6	3.8	3	21	
13/09/2011	22/09/2011	7/08/2020	7.8	46	31.2	6	2	34	
5/07/2011	14/07/2011	7/08/2020	8.6	66	33.5	4.5	6	38	

Environment Protection Licence Number 2384.

Warren Shire Council Sewerage Treatment Plant

Oxley Highway
Warren NSW 2824
Lot 1 DP 1163604

Sample collected at EPA Point No. 2. Quarterly.

Pollutant			PH	Total Suspended Solids TSS	Nitrogen Total	Phosphorus Total	Oil & Grease	Biochemical oxygen demand BOD	
Unit of Measure			PH	Milligrams Per Litre					
Limit			6.5 - 8.5	65	40	10	10	55	
Sample Date	Date Results Obtained	Date Results Published	Red text indicates a result outside of the limits.						
6/04/2011	19/04/2011	7/08/2020	7.8	74	31.8	5.2	6	35	
11/01/2011	18/01/2011	7/08/2020	8.1	24	30.5	4.7	2	26	
5/10/2010	18/10/2010	7/08/2020	7.8	49	30.7	6.2	3	15	